



Owner Statement of Rack or High-Piled Storage

UNION CITY FIRE DEPARTMENT
34009 ALVARDO-NILES ROAD
UNION CITY, CALIFORNIA 94587

PHONE: (510) 675-5470
FAX NO: (510) 487-2117

An annual operating Fire Permit for High-Piled Combustible Storage from the Fire Department is required for storage of combustible materials on closely packed piles or combustible materials on pallets, in racks or on shelves where the top of storage is greater than 12 feet in height. When required by the fire code official, high-piled combustible storage also includes certain high-hazard commodities, such as rubber tires, Group A plastics, flammable liquids, idle pallets and similar commodities, where the top of storage is greater than 6 feet in height.

Additional information required for the annual High-Piled Combustible Storage Fire Permit:

1. A reflected ceiling plan showing the layout of smoke/heat vents on the roof per Table 910.3 of the California Fire Code.
2. Fire fighting access doors may be required as per California Fire Code Chapter 23.
3. In-rack sprinklers may be required as per California Fire Code Chapter 23.
4. Data on existing sprinkler system – density, area of coverage, and sprinkler temperature rating.

Project/Business Name: _____

Project/Address: _____ Union City, CA

Manager/Contact Person: _____ Phone #: _____

The following information is submitted for determination of the type of fire protection devices that might be required. Any deviations may require additional protection after the building is built.

COMMODITY INFORMATION

Describe the commodities to be stored (Combination of product, packing material and container)
